

Minutes of the pre bid meeting held on 04-02-2013 at 3.00 PM in IACS vide NIT No. IACS / WS / SB / 13 /A-05 dtd.21-01-2013.

The meeting was held between the representatives of the manufacturers / Dealers of Airconditioners & in presence of the following officials of IACS.

- 1) **S.N. Bose , Sr. Engineer** (Civil Engg. Dept.)
- 2) **S. Mallik** , Tech . Officer (Workshop)

The questions raised by representatives of A.C. Agencies against the purchase Enquiry (Ref NIT No. IACS / WS / SB / 13 /A-05 dtd.21-01-2013.) notice has been addressed & following discussions here taken .

- 1) Soft drawn copper pipe (thickness not less than 0 .7 MM) shall be installed for suction line & Discharges line .
- 2) 5% of value of the work done duly adjusted with EMD will be kept with IACS for one year from the date completion of work order as security deposit.
- 3) A Bank Draft of **Rs. 500/-** (non refundable) drawn in favour of **Indian Association for the Cultivation Science** has to be submitted along with the Technical Bid in separate envelope as a cost of tender paper , When tender document is downloaded from website .
- 4) The **price bid** in respect of technically qualified bidder shall only be opened with prior intimation to the technically qualified bidders .
- 5) Technical Bid & financial bid duly marked on the top shall be submitted in separate envelopes which are to be put into a third envelop.
- 6) Last date of Submission of offer .(Technical & Financial bid) is **22-02-2013** upto 2.00 PM to the receiving & dispatch section of IACS
- 7) Technical Bid will be opened on **26 – 02 - 2013 at 3. 30PM in presence of Intending bidders.** .
- 8) Financial Bid will be opened on **01- 03 - 2013 at 3.30 PM** in presence of the short listed qualified bidders.
- 9) Higher tonnage will be accepted without any extra price.
- 10) Commissioning certificate along with remote & gurantee card shall be handed over to the Engg. In charge before submission of final bill .

Technical Specification :

Description	Unit	Our Specification	Yours Specification
Manufacturer name			
Model No.			
Tonnage class	TR	2. 0	
Compressor	Type	Rotary / Scroll	
Rated Cooling Capacity	BTU / Hr.	Not Less than 24000	
Rated Cooling Capacity	Watt	Not Less than 6000 Kcal / Hr	
Rated Power Supply	Volt / Hz./ Phase	230 / 50 / 1	
Total Power Input	Watt	2200 to 2450	
Cooling Coil	Material	Copper (not less than . 07 MM thickness)	
Condenser coil	Material	Copper(not less than . 07 MM thickness)	
Suction & discharge Pipe	Material	Copper (not less than . 07 MM thickness)	
Warranty for A.C.	Months	12 months from the date of Installation or 15 months from the date of delivery which ever is earlier	
Warranty for Compressor	Year	1 YEAR	
Delivery	Days	7 to 10 days from the date of receipt of Purchase Order	
Installation	Days	Supplying + Commissioning + Installation = 15 days from the 3rd date of placement of P.O.	
Refrigerant		R-22 / 410	
Cord less Remote Microprocessor Control			
Clamping of Pipe line to be done at an interval of 1 ft.			

with Stamp & Date

Signature of Dealer

Financial Bid Format :

Description	Unit	Quantity	Unit Price	Amount
Manufacturer name				
Model No.				
Price of 2.0 TR Cassette Airconditioners + VAT + Delivery Charges (If Required)				
Installation Charges with Standard Copper Pipe (70 ft.) + Water Pipe(70 ft.) + Electrical Cable (70ft.) + Insulation (70 ft.) + M.S. Fabricated Structure for Out Door unit to be supplied for each Airconditioners				

Stamp & Date

Signature of Dealer with