

Minutes of the pre bid meeting held on 04-02-2013 at 3.00 PM in IACS vide NIT No. IACS / WS / SB / 13 /A-05 dtd.21-01-2013.

The meeting was held between the representatives of the manufacturers / Dealers of Airconditioners & in presence of the following officials of IACS.

- 1) **S.N. Bose , Engineer – I**
- 2) S. Mallik , Tech . Officer (Workshop)

The questions raised by representatives of A.C. Agencies against the purchase Enquiry (Ref NIT No. IACS / WS / SB / 13 /A-05 dtd.21-01-2013.) notice has been addressed & following discussions here taken .

- 1) Soft drawn copper pipe (thickness not less than 0 .7 MM) shall be installed for suction line & Discharges line .
- 2) 5% of value of the work done duly adjusted with EMD will be kept with IACS for one year from the date completion of work order as security deposit.
- 3) A Bank Draft of **Rs. 500/-** (non refundable) drawn in favour of **Indian Association for the Cultivation Science** has to be submitted along with the Technical Bid in separate envelope as a cost of tender paper , When tender document is downloaded from website .
- 4) The **price bid** in respect of technically qualified bidder shall only be opened with prior intimation to the technically qualified bidders .
- 5) Technical Bid & financial bid duly marked on the top shall be submitted in separate envelopes which are to be put into a third envelop.
- 6) Last date of Submission of offer .(Technical & Financial bid) is 21-02-2013 upto 2.00 PM to the receiving & dispatch section of IACS
- 7) Technical Bid will be opened on **22-02-2013 at 3. 30PM in presence of Intending bidders. .**
- 8) Financial Bid will be opened on **26-02-2013 at 3. 30 PM** in presence of the short listed qualified bidders.
- 9) Higher tonnage will be accepted without any extra price.
- 10) Commissioning certificate along with remote & gurantee card shall be handed over to the Engg. In charge before submission of final bill .

Technical Specification :

Description	Unit	Our Specification	Yours Specification
Manufacturer name			
Model No.			
Tonnage class	TR	2. 0	
Compressor	Type	Rotary / Scroll	
Rated Cooling Capacity	BTU / Hr.	Not Less than 24000	
Rated Cooling Capacity	Watt	Not Less than 6000 Kcal / Hr	
Rated Power Supply	Volt / Hz./ Phase	230 / 50 / 1	
Total Power Input	Watt	2200 to 2450	
Cooling Coil	Material	Copper (not less than .07 MM thickness)	
Condenser coil	Material	Copper(not less than .07 MM thickness)	
Suction & discharge Pipe	Material	Copper (not less than .07 MM thickness)	
Warranty for A.C.	Months	12 months from the date of Installation or 15 months from the date of delivery which ever is earlier	
Warranty for Compressor	Year	1 YEAR	
Delivery	Days	7 to 10 days from the date of receipt of Purchase Order	
Installation	Days	Supplying + Commissioning + Installation = 15 days from the 3rd date of placement of P.O.	
Installation Charges with Standard Copper Pipe (70 ft.) + Water Pipe(70 ft.) + Electrical Cable (70ft.) + Insulation (70 ft.) + M.S. Fabricated Structure for Out Door unit to be supplied for each Airconditioners			
Refrigerant		R-22 / 410	
Cord less Remote Microprocessor			

Control			
Clamping of Pipe line to be done at an interval of 1 ft.			

e of Dealer with Stamp & Date

Signatur