

Record notes of Pre-Bid meeting held at the office of IACS on 13.04.2012 for tender of Interior Decoration, partition, False Ceiling, Audio System and other miscellaneous works at Library (Centenary) Building of IACS Jadavpur, Kolkata.

Present

- 1) Shri S N Moulik (Assistant Registrar, IACS)
- 2) Shri S N Bose (Engineer, IACS)
- 3) Shri A Sarkar (Assistant Engineer, Civil, IACS)
- 4) Shri A Mukherjee (Sr Engineer, GBA)
- 5) Shri G Chanda (Engineer, Civil, GBA)

During the meeting the points regarding the schedule of works raised by the intending bidders have been discussed and clarified as under :

- a) The earnest money deposit in the form of Bank guarantee will not be accepted, as per terms of Tender.
- b) The arrangement for water & power supply shall have to be made by the contractor in accordance to clause No. 56 & 57 under general condition of contract.
- c) The tenderer shall include all taxes, royalties, cess, vat and any other taxes/charges if applicable and no extra claim on this account will in any case be entertained. Ref clause No. 16 under GCC.

Page No.	SI No.	Please read as	Instead of
I - 1	1	.....4.0 mm dia G I Wire.....	.....40 mm dia G I Wire.....
I - 2	2	.....8 mm thick calcium silicate board of approved quality.....	.....8 mm thick calcium silicate board of approved size.....
I - 2	3(b)	3.5 mm decorated veneer on top- the basic price is Rs.450.00 to 550.00 per Sqm.	
I - 3	6	Providing & fixing magnetic (ceramic finish) white board with magnetic catcher.....	Providing & fixing white board with magnetic catcher.....

I-4	7	.....Stainless steel tower bolt 250 mm long.....	.....Stainless steel tower bolt 25 mm.....
I-4	8(a)	1.0 mm thick laminates - the basic price is Rs.400.00 to 450.00 per Sqm.....	
I-5	11	For Vertical Blinds – the basic price is Rs.1,356.00 per Sqm.	
I-5	12	Full height storage cabinet as described in the schedule.	Full height storage cabinet (as per drawing).....
I-5	13	Overall dimension of speaker podium is 750 x 550 x 1350 mm (height)	
I-6	15	Chalk Board surrounded all around by 75 x 25 mm teak wood bead frame work.	
I-6	18	.....Vertical post of 100 mm x 100 mm wooden post /stubs.....  Main runners of size 75 x 50 mm Sal wood.	.....Vertical post of 75 mm x 75 mm wooden post /stubs.....
I-7	19	.....8 mm thick laminated wooden flooring of (pergo/sq.foot or equivalent make).....  The basic price is Rs.1,600.00 to 1,800.00 per Sqm.	..... laminated wooden flooring of (perge/sq.foot or equivalent make).....
I-7	21	Technical specification: The tile should have a capacity to withstand a concentrated load of 540 Kgs, ultimate concentrated load of 1350 Kgs and rolling load of 270 Kgs.	The tile should have a capacity to withstand a point load of 360 Kgs, uniform distributed load of 1600 Kg/Sqm.

		Fire rating – the panel shall confirm to class – ‘O’ & class – ‘I’ fire rating tested as per BS : 476 parts 6 & 7. Electrical resistivity – As per ASTM F150/NFPA99.	
I - 8	28	Providing & fixing heavy type floor spring of approved make.....	Providing & fixing floor spring heavy type (hardwyn).....
I - 9	30	PVC vinyl rolls flooring – the basic price is Rs.345.00 to 375.00 per Sqm.	
SQ - 4	1(ix)	For DLP Multimedia Projector, the make ‘OPTOMA’ is included with others.	
SQ - 5	1 (xii)	Motor Screen alongwith remote control – Diagonal width of the screen is 100” (inch) and the make ‘DRAPPER’/‘OPTOMA’ are included with others.	
C - 1	1	Non-skid jointless marbles series vitrified tiles – the basic price is Rs.800.00 to Rs.850.00 per Sqm.	
67	12(d)	List approved ply : Austin, Century, Green,Duro (ISI marked), Globe	List approved ply : Austin, Century, Green,Dund (ISI marked), Globe

**Special notes for Audio, Video & Control System :**

The contractor shall have to provide copy of all invoices alongwith manufacturer's Test Certificates and guarantee cards duly authenticated by the manufacturer/authorized dealer and shall be responsible for perfect performance of the total system as well as all appliances till defect liability period. The work shall be executed through a specialized agency whose details shall be submitted by the contractor for approval of owner/consultant. However, that shall not relieve the contractor from any of his obligation under this contract and he will remain fully responsible for completeness, accuracy and perfect performance according to ambience upto the satisfaction of the owner.

You are requested to consider the above modifications and submit your offer accordingly. Please note that this letter shall form part of the tender documents and to be submitted with your offer in **Cover – II** duly signed with official seal.